

VOC Content Test Certificate

Monday April 2nd, 2012

Manufacturer: Bostik NZ (19 Eastern Hutt Rd, Wingate, Lower Hutt, NZ 5019)

Sample Description: Coolroom Sealant CR6S

Date Tested: April 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in
Various Materials as referenced by South Coast Air Quality Management District
(SCAQMD) Rule 1168

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Coolroom Sealant CR6S
Architectural sealant 250 grams per Litre as VOC content per material	100 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120302